

OFFICE OF THE CHIEF ENGINEER-1, HUDA C-3, SECTOR-6, PANCHKULA

To

All the Administrator,
HUDA in the State

All the Superintending Engineers,
HUDA in the State.

All the Executive Engineer,
HUDA in the State

Memo No: C.E.-1 /EE (W)/CHD (F)/14/2650-57 Dated: 25/2/14

Handwritten notes:
3-3-14
4/3/14
AM(60)
5367
3-3-14

Sub:

Land requirement norms for construction of STPs in various Urban Estates of HUDA.

It has been observed tht there are no fixed norms for requirement of land for constructioof STPs in various Urban Estates in HUDA. In the field offices the site got earmarked for STPs without considering the technology to be adopted for land requirement.

As per various tested/recommended technologies available in the market i.e. ASP/SBR/MBR/MBBR/FAB/USAB etc the land requirement for STP is varying from 0.25 acre/MLD to 1.00 Acre/MLD.

Keeping in view the above, it has been decided that in future land norms of 0.25 acre/MLD be taken for getting the land earmarked in the Development Plans accordingly in view of requirement of capacity of STPs.

This is with the approval of Worthy Chief Administrator, HUDA, Panchkula.

Handwritten signature: 24/2
**Executive Engineer (W),
For Chief Engineer-1,
HUDA, Panchkula.**
Handwritten date: 22/2/2014

CC to

1. The Chief Town Planner, Haryana for information & necessary action
2. The Chief Town Planner, HUDA Panchkula for information and necessary action.
3. E.E(W)/E.E.(HQ)/E.E.(M) for information and necessary action.
4. P.S. to C.A. HUDA for kind information of Worthy Chief Administrator, HUDA, Panchkula.
5. P.A. to C.E./C.E.-1, HUDA Panchkula for kind information to Chief Engineer/Chief Engineer-1, HUDA, Panchkula